

DICHIARAZIONE DI CONFORMITA'
 CONFORMITY DECLARATION
 DECLARATION DE CONFORMITÈ
 KONFORMITÄTSEKLAERUNG

CATEGORY: A3.3

Il Costruttore
 The Company
 La société
 Die Firma

Refrigerera S.R.L.

Via Chiavornicco, 76
33084 CORDENONS (PN), ITALIA

dichiara che la
 declares that the
 déclare que la
 erklärt dass die

valvola a sfera con tuberie in lega CuFe2P idonea per alta pressione
 ball valve with CuFe2P-alloy connections suitable for high pressure
 soupape de balle avec CuFe2P tubes adapté à haute pression
 Kugelabsperventil mit CuFe2P-Rohre für Hochdruck

modello: type: model: Modell:

REF1.1.N.A.010.K65	REF1.1.S.A.038.K65	REF1.1.N.B.015.MK65	REF1.1.S.B.015.MPK65
REF1.1.N.A.038.K65	REF1.1.S.A.012.K65	REF1.1.N.B.016.MK65	REF1.1.S.B.016.MPK65
REF1.1.N.A.012.K65	REF1.1.S.A.127.K65	REF1.1.N.B.018.MK65	REF1.1.S.B.018.MPK65
REF1.1.N.A.127.K65	REF1.1.S.B.015.K65	REF1.1.N.B.034.MK65	REF1.1.S.B.034.MPK65
REF1.1.N.B.015.K65	REF1.1.S.B.016.K65	REF1.1.N.C.022.MK65	REF1.1.N.B.015.MPK65
REF1.1.N.B.016.K65	REF1.1.S.B.018.K65	REF1.1.N.D.028.MK65	REF1.1.N.B.016.MPK65
REF1.1.N.B.018.K65	REF1.1.S.B.034.K65	REF1.1.N.D.118.MK65	REF1.1.N.B.018.MPK65
REF1.1.N.B.034.K65	REF1.1.S.A.010.MK65	REF1.1.N.E.035.MK65*	REF1.1.N.B.034.MPK65
REF1.1.N.C.022.K65	REF1.1.S.A.038.MK65	REF1.1.N.F.042.MK65*	REF1.1.N.C.022.MPK65
REF1.1.N.D.028.K65	REF1.1.S.A.012.MK65	REF1.1.N.F.158.MK65*	REF1.1.N.D.028.MPK65
REF1.1.N.D.118.K65	REF1.1.S.A.127.MK65	REF1.1.S.A.010.MPK65	REF1.1.N.D.118.MPK65
REF1.1.N.E.035.K65*	REF1.1.S.B.015.MK65	REF1.1.S.A.038.MPK65	REF1.1.N.E.035.MPK65*
REF1.1.N.F.042.K65*	REF1.1.S.B.016.MK65	REF1.1.S.A.012.MPK65	REF1.1.N.F.042.MPK65*
REF1.1.N.F.158.K65*	REF1.1.S.B.018.MK65	REF1.1.S.A.127.MPK65	REF1.1.N.F.158.MPK65*
REF1.1.S.A.010.K65	REF1.1.S.B.034.MK65	-	-

* Classification according to inside sphere- port = 32mm

è conforme alla direttiva 97/23/CE (PED)

is in accordance with directives 97/23/CE (PED)

est conforme à les directives 97/23/CE (PED)

Entspricht Druckbehälter Richtlinie 97/23/CE (PED)

Conformity and assessment procedure followed: (ref. annex II / annex III - 97/23/CE)

Refrigerant	Max working pressure	Upper/Lower T limits	DN (Sphere Passage)	PSxDN	Category	Module
Fluid Group 2	120 bar*	+150/- 40°C	≤32mm	≤1000	A 3.3	-

*salvo diversamente indicato sulla valvola / unless otherwise indicated / à moins d'indication contraire / sofern nicht anders

Norme armonizzate osservate:

Other regulations observed:

Autres normes respectées:

Andere entsprechende normen / Bestimmungen:

EN 378-2; EN 9606-3; EN 970;
 EN 1593; EN 12284(§9); EN 13445-3;
 EN 14276-2.

Cordenons, 15/12/2011


Il legale rappresentante

Administrator

Amministrateur

Geschäftsführer

Agatino Maurizio Papa



REFRIGERA SRL Società Uninomiale

Capitale Soc.: € 98.800,00 i.v.

Via Chiavornicco, 76 – 33084 Cordenons (PN) – ITALIA

Registro Imprese di PORDENONE N. Reg. Impr., C.F. e P.Iva: IT01403180936

TEL: 0434 / 542266 – FAX 0434 / 542267

WEB: www.refrigerera.eu – EMAIL: info@refrigerera.eu