

DICHIARAZIONE DI CONFORMITA'
CONFORMITY DECLARATION
DECLARATION DE CONFORMITÈ
KONFORMITAETSERKLAERUNG

CATEGORY: A3.3

Il Costruttore

The Company
 La società
 Die Firma

Refrigera S.R.L.

Via Chiavornicco, 76
33084 CORDENONS (PN), ITALIA

dichiara che i
 declares that the
 déclare que les
 erklärt dass die

Raccordi filettati in ottone
 Brass threaded fittings
 Raccords filetés en laiton
 Messing Gewindefittings

modello: type: model: Modell:

B1-3, B1-4, B1-5, B1-6, B1-8, B1-10, B1-12, B1-14
 B2-3, B2-4, B2-5, B2-6, B2-8, B2-10, B2-12, B2-14
 B3-3, B3-4, B3-5, B3-6, B3-8, B3-10, B3-12, B3-14,
 CAP-02, CAP-03
 CC-01, CC-02, CC-03, CC-04
 E1-4A, E1-4B, E1-6B, E1-6C, E1-8C, E1-8D
 E1-10D
 E1-12F
 E2-4, E2-6, E2-8, E2-10, E2-12
 E3-4, E3-6, E3-8
 MC-05, MC-06
 N5-4, N5-5, N5-6, N5-8
 NRS4-64, NRS4-86, NRS4-108, NRS4-1210, NRS4-1614
 NS4-4, NS4-4M6, NS4-5, NS4-6M6, NS4-5M8, NS4-6, NS4-65,
 NS4-6M8, NS4-6M10, NS4-8, NS4-8M10, NS4-8M 12, NS4-10,
 NS4-10M12, NS4-10M14, NS4-10M16, NS4-12, NS4-12M14, NS4-
 12M16, NS4-12M18, NS4-14, NS4-14M22, NS4-16, NS4-16M22
 RI-44, RI-66, RI-88, RI-1010

SFN4-4, SFN4-6, SFN4-8
 T1-4A, T1-4B, T2-4, T2-6, T2-8, T2-10, T2-12, T6-4
 TC-01, TC-02, TC-03, TC-04
 TR2-46, TR2-64, TR2-68, TR2-86, TR2-810, TR2-108, TR2-1012,
 TR2-1210
 U1-4A, U1-4B, U1-6B, U1-6C, U1-8C, U1-8D, U1-10D, U1-12F
 U2-4, U2-6, U2-8, U2-10, U2-12
 U3-4A, U3-4DX
 UC-01, UC-01X50, UC-01X100, UC-02, UC-03, UC-4A, UC-4B, UC-4C, UC-
 05, UC-06, UC-07, UC-08, UC-09, UC-09X50, UC-09X100, UC-10
 UP3-4G4F, UP3-4G4M, UP3-4, UP3-6, UP3-8
 UR2-64, UR2-84, UR2-86, UR2-104, UR2-106, UR2-108, UR2, UR2-1210,
 UR2-128
 UR3-46, UR3-64, UR3-68, UR3-84, UR3-86, UR3-810, UR3-812, UR3-108,
 UR3-1012, UR3-128, UR3-1210
 US3-44, US3-4M6, US3-4M8, US3-66, US3-6M10, US3-88, US3-8M12,
 US3-1010, US3-10M 16, US3-12M18
 US4-4, US4-5, US4-6, US4-8, US4-10

è conforme alla direttiva 97/23/CE (PED)

is in accordance with directives 97/23/CE (PED)

est conforme à les directives 97/23/CE (PED)

Entspricht Druckbehälter Richtlinie 97/23/CE (PED)


Conformity and assessment procedure followed: (ref. annex II / annex III - 97/23/CE)

Refrigerant	Max working pressure	Upper/Lower T limits	DN	PSxDN	Category	Module
Fluid Group 2	45 bar	+80 / - 30°C	≤32mm	≤1000	A 3.3	-
Norme armonizzate osservate:				EN378; EN 12284; EN 16084;		
Other regulations observed:				EN 12165; EN 12164; EN 12449;		
Autres normes respectées:				ISO1629 ; ASTMD1418 ; EN17672		
Andere entsprechende normen / Bestimmungen:						

Cordenons, 15/12/2011

Il legale rappresentante

Administrator
 Amministrateur
 Geschäftsführer
Agatino Maurizio Papa



REFRIGERA SRL Società Uniminale
 Capitale Soc.: € 98.800,00 i.v.

Via Chiavornicco, 76 – 33084 Cordenons (PN) – ITALIA
 Registro Imprese di PORDENONE N. Reg. Impr., C.F. e P.Iva: IT01403180936
 TEL: 0434 / 542266 – FAX 0434 / 542267
 WEB: www.refrigera.eu – EMAIL: info@refrigera.eu